


157
WATER POLLUTION ABATEMENT PROGRAM

145470
VILLAGE OF SAUGET, ILLINOIS

FLOW MEASUREMENT REPORT

DECEMBER 22, 1970



Monsanto
BIODIZE SYSTEMS, INC.

VS0541

Monsanto

Monsanto Biodize Systems Inc.
510 Northern Boulevard
Great Neck, New York 11021
Phone: (516) 466-5511

December 22, 1970

Village of Sauget Board of Trustees
2897 Monsanto Avenue
Sauget, Illinois 62206

Attn: The Honorable Paul Sauget
President of Board of Trustees

Gentlemen:

In accordance with the agreement between the Village of Sauget and Monsanto Biodize Systems, Inc., we submit herewith a report of the results of our flow measurement work.

Very truly yours,



Jerry L. Jones
Prototype Plants Supervisor

JLJ:rs



TABLE OF CONTENTS

	<u>Page</u>
OBJECTIVES - - - - -	1
CONCLUSIONS - - - - -	2A - 3
PROCEDURE FOR FLOW DETERMINATION - - - - -	4 - 6
FLOW MEASUREMENT RESULTS	
North Trunk Sewer - - - - -	7 - 8
South Trunk Sewer - - - - -	8 - 9
West Trunk Sewer - - - - -	9
Summary of Contributions - - - - -	9 -11
SUSPENDED SOLIDS RESULTS - - - - -	12 -14
DISTRIBUTION OF PRIMARY TREATMENT PLANT	
OPERATING COSTS - - - - -	15 -16
APPENDIX I	Village of Sauget North Trunk Sewer Flow Data and Data Analysis - - - - -
	17 -43
APPENDIX II	Village of Sauget South Trunk Sewer Flow Data and Data Analysis - - - - -
	44 -57
APPENDIX III	Village of Sauget West Trunk Sewer Flow Data and Data Analysis - - - - -
	58 -64
APPENDIX IV	Average Waste Water Flows at Village of Sauget Sample Stations - Flow Calculations for Individual Contributors-64-69
APPENDIX V	Average Suspended Solids Concentrations at Village of Sauget Sample Stations - Suspended Solids Calculations for Individual Contributors - - - - -
	70 -73
APPENDIX VI	Results of Metcalf & Eddy Waste Characterization and Operating Cost Distribution for the Village of Sauget Primary Treatment Plant - - - - -
	74-75

DISTRIBUTION LIST

	<u>Copies</u>
Village of Sauget Board of Trustees	11
Monsanto Biodize Systems, Inc.	
Messrs. E. L. Boehm	1
G. T. Flint	1
W. W. Haase	1
J. L. Jones	1
C. L. Knowles, Jr.	1
J. Starzyk	1
W. F. Suchanek, Jr.	1
A. J. Young	1
File	<u>2</u>
	21

WATER POLLUTION ABATEMENT PROGRAM

VILLAGE OF SAUGET, ILLINOIS

DECEMBER 22, 1970

Prepared by:

Jerry L. Jones

Jerry L. Jones
Prototype Plants Supervisor

LIST OF FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
1	Location of Injection & Sampling Station for Li Cl Flow Measurement Work-Village of Sauget Sewer System -	5
I-1	Plot of Flow Data - Sample Station N-1 - - - - -	18
I-2	Frequency Distribution - Flow Data - Sample Station N-1 - - - - -	19
I-3	Plot of Flow Data - Sample Sta. N-2 -	21
I-4	Frequency Distribution - Flow Data - Sample Station N-2 - - - - -	22
I-5	Plot of Flow Data - Sample Sta. N-3 -	24
I-6	Plot of Flow Data - Sample Sta. N-4 -	26
I-7	Frequency Distribution - Flow Data - Sample Station N-4 - - - - -	27
I-8	Plot of Flow Data - Sample Station N-5 -	29
I-9	Frequency Distribution - Flow Data - Sample Station N-5 - - - - -	30
I-10	Plot of Flow Data - Sample Sta. N-6 -	32
I-11	Frequency Distribution - Flow Data - Sample Station N-6 - - - - -	33
I-12	Plot of Flow Data - Sample Sta. N-7 --	35
I-13	Plot of Flow Data - Sample Sta. N-8 -	37
I-14	Frequency Distribution - Sample Sta. - N-8 - - - - -	38
I-15	Plot of Flow Data - Sample Sta. N-9 -	40
I-16	Plot of Flow Data - Sample Sta. N-10 -	42
I-17	Frequency Distribution - Sample Sta. N-9 and N-10 - - - - -	43
II-1	Plot of Flow Data - Sample Stations S-1 and S-2 - - - - -	46

LIST OF FIGURES (continued)

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
II-2	Plot of Flow Data - Sample Sta. S-3 - - - - -	48
II-3	Frequency Distribution - Flow Data- Sample Stations S-3 - - - - -	49
II-4	Plot of Flow Data - Sample Sta. S-4 -	51
II-5	Frequency Distribution - Flow Data- Sample Station S-4 - - - - -	52
II-6	Plot of Flow Data - Sample Sta. S-5 -	54
II-7	Frequency Distribution - Flow Data Sample Station S-5 - - - - -	55
II-8	Plot of Flow Data - Sample Sta. S-6 -	57
III-1	Plot of Flow Data - Sample Stations S-7 and S-8 - - - - -	60
III-2	Frequency Distribution - Flow Data- Sample Stations S-7 and S-8 - - - -	61
III-3	Plot of Flow Data - Sample Stations- W-1 and W-2 - - - - -	64

LIST OF TABLES

<u>Table Number</u>	<u>Title</u>	<u>Page</u>
1	Village of Sauget - Waste Water Distribution	11
2	Suspended Solids Distribution	14
3	Village of Sauget - Primary Treatment Plant Operating Costs Distribution	16
I-1	Flow Data - Sample Station N-1	17
I-2	Flow Data - Sample Station N-2	20
I-3	Flow Data - Sample Station N-3	23
I-4	Flow Data - Sample Station N-4	25
I-5	Flow Data - Sample Station N-5	28
I-6	Flow Data - Sample Station N-6	31
I-7	Flow Data - Sample Station N-7	34
I-8	Flow Data - Sample Station N-8	36
I-9	Flow Data - Sample Station N-9	39
I-10	Flow Data - Sample Station N-10	41
II-1	Flow Data - Sample Station S-1	44
II-2	Flow Data - Sample Station S-2	45
II-3	Flow Data - Sample Station S-3	47
II-4	Flow Data - Sample Station S-4	50
II-5	Flow Data - Sample Station S-5	53
II-6	Flow Data - Sample Station S-6	56
III-1	Flow Data - Sample Station S-7	58
III-2	Flow Data - Sample Station S-8	59
III-3	Flow Data - Sample Station W-1	62
III-4	Flow Data - Sample Station W-2	63
IV-1	Village of Sauget Sewer System Average Waste Water Flows	65-67

LIST OF TABLES (continued)

<u>Table Number</u>	<u>Title</u>	<u>Page</u>
V-1	Suspended Solids Data	70
V-2	Village of Sauget Sewer System Suspended Solids	71
VI-1	Metcalf & Eddy - Estimated Quantities of Waste Materials to be Treated	74
VI-2	Estimated Annual Operating and Maintenance Costs	75

OBJECTIVES

The objectives of this study were to:

- (1) measure the volume of water being discharged by the individual industries and the residential areas of the Village of Sauget, Illinois.
- (2) measure the level of the suspended matter in the waste water discharges of the contributing industries and residential areas.
- (3) present a revised rate schedule for distributing the operating costs for the Village of Sauget Treatment Plant among contributing industries and the Village of Sauget.
- (4) gather proportionate to flow samples for general analytical characterization. The results of these tests are to be presented in reports of treatability work and overall waste characterization.

RESULTS AND CONCLUSIONS

The basis for the distribution of operating costs for the Village of Sauget Treatment Plant has been specified as the amount of the contribution of waste water and suspended matter to the facility. Mobil Oil Company's waste contribution has become very insignificant since their shutdown during the first part of October, 1970. Cerro Copper and Brass Company's waste flow contribution has increased significantly from 5.58% of the total to 10.48% of the total. All other flow proportions remained at nearly the same level.

The changes in the measured amounts of suspended matter being discharged were quite significant compared with those found in previous studies. Monsanto's discharges increased 55.4% over the previous level or from 12,000 lbs. per day to 18,657 lbs. per day. Midwest Rubber's discharges decreased from 10,000 lbs. per day to 2,250 lbs. per day or 77.5%. Cerro Copper and Brass's contribution increased from 1,600 lbs. per day to 5,280 lbs. per day or a 2.3 fold increase. The total lbs. per day of solids handled by the treatment plant, however, has increased by only 7%. A distribution of 68.5% of the operating cost to the flow contribution and 31.5% of the cost to the solids contribution has been used for proportioning the operating costs of the primary facility.

RESULTS AND CONCLUSIONS (Continued)

The following summary table shows the previous distributions and the revised distributions resulting from the Monsanto Biodize Systems' study.

SUMMARY

VILLAGE OF SAUGET PRIMARY TREATMENT PLANT

DISTRIBUTION OF OPERATION COSTS

<u>Contributor</u>	<u>Revised Equalized Avg. Flow MGD</u>	<u>Revised Distrib. % of Flow</u>	<u>Previous Distrib. % of Flow</u>	<u>Revised Equal.Sus. Solids (lbs/day)</u>	<u>Revised Distrib. % of Sol.</u>	<u>Previous Distrib. % of Solids</u>	<u>Revised Distrib.of Treatment % Costs</u>	<u>Previous Distrib. % of Costs</u>
American Zinc Company	4.33	18.254	21.23	2,160	7.660	9.50	<u>14.848</u>	15.60
Cerro Copper & Brass Co.	2.50	10.480	5.58	5,122	18.166	5.24	<u>12.901</u>	5.42
Mobil Oil Company	0.014	0.758	5.89	7	0.025	14.41	<u>0.048</u>	9.99
Monsanto Company	14.80	62.047	61.14	18,657	66.168	43.57	<u>63.345</u>	52.70
Midwest Rubber Reclaiming	2.08	8.720	5.87	1,845	6.543	27.19	<u>8.034</u>	16.10
Sterling Steel Casting Co.	0.072	0.303	0.29	75	0.268	0.09	<u>0.292</u>	0.19
Village of Sauget*	<u>0.042</u>	<u>0.128</u>	<u>0</u>	<u>330</u>	<u>1.170</u>	<u>-</u>	<u>0.532</u>	<u>-</u>
	23.836	100.000	100.000	28,196	100.000	100.000	100.000	100.000

*Includes Rogers Cartage Company Waste Discharges

PROCEDURE FOR FLOW DETERMINATION

The basic plan for the measurement of the flows from the individual industries and residential areas within the Village of Sauget was outlined in the Monsanto Biodize Systems Proposal dated July 31, 1970.

Preliminary work was done within each plant to determine the order of magnitude of the various water discharges. Fluorescein dye was used as a tracer to check sewer maps and observe distance required for adequate mixing. Good mixing is of the utmost importance for obtaining reliable results from salt dilution flow measuring techniques. Velocity measurements, pump operating times at lift stations, and in process inspections were used to determine the necessary salt injection rates for the various sewers.

The injection and sample stations have been shown in Figure 1. A tabulation of all the sample and injection stations as well as a description of the flow sources of these points has been included in Appendix IV, pages 65-67.

The program was planned so that all discharges along the North Trunk Sewer would be measured during the period from September 16, 1970, thru September 23, 1970, and those discharges to the South and West Trunk sewers during the period from September 25, 1970, thru October 1, 1970. A shut-down at the American Zinc Company during the flow determination study conducted on September 21, prevented

completion of the North Trunk work during the designated time period. A subsequent shutdown at the Midwest Rubber Company prevented the scheduled completion of the flow measurement work on the West Trunk sewer. This work was completed during the period from December 5, 1970, to December 11, 1970.

FLOW MEASUREMENT RESULTS

NORTH TRUNK SEWER

All data for the North Trunk Sewers has been shown in Appendix I. The flow from the Mobil Oil Refinery was determined from measurements at sample stations N-1 and N-7 before the refinery shutdown and was approximately 1.6 MGD. After the refinery shut-down a spot check indicated that the total waste flow will be less than 10 gpm. Mr. H. Kilabrew of Mobil informed us that none of their deep wells will be used and that the only waste water will come from the sanitary sewer system and steam blowdown. The Sanitary Development and Research Association should be informed of any changes in the water discharge rate due to changes in operation or plant equipment cleaning.

Sample stations N-2, 3, 4, and 5 provided flow data for the discharges from the North Area of the Monsanto Plant while the two discharges from the Main Plant area to the North Trunk Sewer were measured at sample stations N-7 and N-8. The results are shown in Appendix I, pages 17-23, and Appendix IV, pages 65-67.

The sum of the flows measured at sample stations N-1, 2, 3, 4, and 5 should equal the combined flow measured at station N-6 after the American Zinc Company shutdown during the afternoon of September 21, 1970. The flows, however, do not balance and this may either be attributed to continued use of some water by American

NORTH TRUNK SEWER (continued)

Zinc Company or unusually high discharges from the two sewers flowing into the North Trunk sewer from Monsanto's Main Plant area.

The results of the flow determination work for the American Zinc Company have been shown in Appendix I, pages 39-43, and Appendix IV, pages 65-67.

SOUTH TRUNK SEWER

All data for the South Trunk Sewer has been shown in Appendix II. Sterling Steel Casting Company's only use of well water is for air conditioning units. The marked drop in the water being discharged from their plant at sample station S-1 may be attributed to the shutdown of the air conditioning units during the evening of September 25, 1970. (Note Appendix II, Figure II-1, page 46.

The Village of Sauget residential area discharges plus Sterling Steel Casting Company and the Rogers Cartage Company discharges, were measured at sample station S-2.

The volume of water from Cerro Copper and Brass Company which flows into the outlet of Dead Creek was measured at sample station S-4. (Note Appendix II, Pages 50 - 52.

From the flows measured at sample stations S-2, 3, 4, and 5, a flow balance for the 24 inch South Trunk Sewer

SOUTH TRUNK SEWER (continued)

could be made and the flows distributed among the contributing sources. (Note Appendix II, pages 44-55 and Appendix IV, pages 65-67.)

WEST TRUNK SEWER

Sample stations S-7 and S-8 for Cerro Copper and Brass are for discharges to the West Trunk Sewer. Flows from Midwest Rubber were measured at sample stations W-1 and W-2. (Note Appendix III and Appendix IV, pages 58-64.)

SUMMARY OF CONTRIBUTIONS

The calculations for the proportioning of flows between the Village of Sauget and the various industries has been shown in Appendix IV, pages 68-69.

If there are any consistent major fluctuations during a normal working week, the waste water discharges from the various contributors must be equalized over a 7 day period.

No such fluctuations occur for the following contributors:

- (a) American Zinc Company
- (b) Mobil Oil Company
- (c) Monsanto Company
- (d) Sterling Steel Casting Company
- (e) Village of Sauget

Cerro Copper and Brass Company does not cast copper on approximately 50% of the Saturdays during the year and 100% of the Sundays. This would decrease the water discharge

SUMMARY OF CONTRIBUTIONS (continued)

by about 250 gpm which is normally used for makeup water to the quench tanks. This decrease in water usage is approximately 14% for 21% of the year.

$$\text{Equalized Flow} = (0.79)(\text{Avg Flow}) + (0.21)(0.86) \\ (\text{Avg. Flow})$$

$$\text{Equalized Flow} = (0.79 + 0.18)(\text{Avg Flow})$$

$$\text{Equalized Flow} = (0.97)(\text{Avg Flow})$$

Midwest Rubber Company has partial production on Saturdays and no production on Sundays. The water discharges on Saturdays are approximately 75% of normal usage.

$$\text{Equalized Flow} = (0.75)(\text{Avg Flow})(1/7) + (5/7)(\text{AvgFlow})$$

$$\text{Equalized Flow} = \{(0.105) + (0.715)\} \text{ Avg Flow}$$

$$\text{Equalized Flow} = (0.82) (\text{Avg Flow})$$

The flow distribution results are listed in Table #1.

TABLE #1

VILLAGE OF SAUGET
WASTE WATER DISTRIBUTION

<u>Contributor</u>	<u>Avg. Flow (gpm)</u>	<u>Equalization Factor</u>	<u>Equalized Avg. Flow (gpm)</u>	<u>Equalized Avg. Flow (MGD)</u>	<u>New Distrib. % of Flow</u>	<u>Old Distrib. % of Flow</u>
American Zinc Company	3,020	1	3,020	4.33	18.154	21.23
Cerro Copper & Brass Co.	1,800	0.97	1,745	2.50	10.480	5.58
Mobil Oil Co.	10	1	10	0.014	0.058	5.89
Monsanto Co.	10,315	1	10,315	14.80	62.047	61.14
Midwest Rubber Co.	1,765	0.82	1,450	2.08	8.720	5.87
Sterling Steel Casting Co.	50	1	50	0.072	0.303	0.29
Village of Sauget	<u>30</u>	<u>1</u>	<u>30</u>	<u>0.042</u>	<u>0.238</u>	<u>0</u>
TOTALS	16,900			23.836	100.000	100.00
	24.4 MGD					

11

SUSPENDED SOLIDS RESULTS

Flow proportioned samples were composited for the various sample points and the level of suspended matter was measured. Solids contributions were calculated directly or indirectly from material balances. All data and calculations have been shown in Appendix V, pages 70-73.

Results are tabulated in Table #2.

The changes in the measured amounts of suspended matter being discharged were quite significant from those found in previous studies. Monsanto increased 55.4% over the past measured level or from 12,000 lbs/day to 18,657 lbs/day. Midwest Rubber decreased from 10,000 lbs/day to 2,250 lbs/day or 77.5%. Cerro Copper and Brass's contribution increased from 1,600 lbs/day to 5,280 lbs/day or a 2.3 fold increase. American Zinc's solids contribution decreased approximately 20% from 2,600 to 2,160 lbs/day. The total lbs/day of solids handled by the treatment plant, however, has changed by only about 7%.

The 28,196 lbs/day of suspended matter would correspond to an influent concentration of approximately 130 to 140 mg/l. The average value for the concentration of suspended matter we have observed in the influent flow to the treatment plant for the months of November and December of this year has been 240 mg/l. The mean (\bar{X}), however, has been approximately 125 mg/l.

SUSPENDED SOLIDS RESULTS (continued)

During the testing period grab samples were taken at Midwest Rubber Company to determine if our automatic - continuous samplers were obtaining a true sample of the waste being discharged. Automatic samplers tend to take a sample which contains a lower amount of suspended matter than actually contained in the waste stream for certain particle size distributions. Grab samples, however, showed lower concentrations than those observed during the continuous sampling program. Midwest's lower solids level can probably be attributed to better control of dumping according to Mr. R. Rhinehart of Midwest Rubber. Special attention should be given to the West Area of the plant in the vicinity of the silos and shredding operations to prevent solid discharges from storm runoff.

Monsanto's increase in solids came from the high solids level in the 30" South Trunk Sewer. Perhaps more data over an extended period of time, which was beyond the scope of this project, will indicate that an abnormal period of operation occurred during this study.

TABLE # 2

SUSPENDED SOLIDS DISTRIBUTION

	<u>Lbs. solids per day</u>	<u>Equalization Factor</u>	<u>Equalized lbs. solids per day</u>	<u>New Distrib. % of Solids</u>	<u>Old Distrib. % of Solids</u>
American Zinc Co.	2,160	1	2,160	7.660	9.50
Cerro Copper & Brass	5,280	0.97	5,122	18.166	5.24
Mobil Oil Company	7	1	7	0.025	14.41
Monsanto Company	18,657	1	18,657	66.168	43.57
Midwest Rubber Co.	2,250	0.82	1,845	6.543	27.19
Sterling Steel Co.	75	1	75	0.268	0.09
Village of Sauget	330	1	<u>330</u>	<u>1.170</u>	<u>-</u>
			28,196	100.000	100.00

DISTRIBUTION OF PRIMARY TREATMENT PLANT OPERATING COSTS

The most equitable basis for distribution of operating costs for the primary treatment facility is by equating costs to the amount of suspended matter, floating scum and flow contributed by each user. Metcalf & Eddy neglected to include floating oil or scum in their estimate and this oil has involved many man hours of labor for skimming from the treatment plant, and caused problems in the drying of the sludge in the sludge lagoons. Now that Mobil Oil Company has ceased operations, however, floating oil is no longer a major problem at the treatment plant.

Metcalf & Eddy estimate the waste quantities and these have been shown in Appendix VI, page 74. The distribution of a given operating cost is all that we are concerned with for the purposes of this report. Metcalf & Eddy's distribution of ^{61.65%} 68.5% of the cost to flow and ^{38.35%} 31.5% to suspended matter has been taken as the basis for distributing the costs using the data we have presented. (Note Appendix VI, page 75).

Table 3 shows the new cost distribution for the treatment plant.

TABLE #3

VILLAGE OF SAUGET PRIMARY TREATMENT PLANT
OPERATING COSTS DISTRIBUTION

<u>Contributor</u>	<u>% of Susp.Mtr. lbs/day</u>	<u>% of Trtmt.Costs (SM)</u>	<u>% of Flow</u>	<u>% of Trtmt.Costs (Flow)</u>	<u>Revised Total % of Trtmt.Costs</u>	<u>Previous Total % of Trtmt. Costs (May-Sept)</u>	<u>(Oct-Apr)</u>
American Zinc Company	7.660	2.413	18.154	12.435	14.848	15.60	15.62
Cerro Copper & Brass Co.	18.166	5.722	10.480	7.179	12.901	5.42	5.42
Mobil Oil Co.	0.025	.008	0.058	.040	0.048	9.99	10.00
Monsanto Co.	66.163	20.843	62.047	42.502	63.345	52.70	52.78
Midwest Rubber Reclaiming Co.	6.543	2.061	8.720	5.973	8.034	16.10	16.12
Sterling Steel Casting Co.	0.268	0.084	00.303	0.208	0.292	0.19	0.06
Village of Sauget	1.170	0.369	0.238	0.163	<u>0.532</u>	<u>-</u>	<u>-</u>
					100.000	100.00	100.00

APPENDIX I

VILLAGE OF SAUGET
NORTH TRUNK SEWER
FLOW DATA AND DATA ANALYSIS

Table I-1.
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background) 1% Concent.

JOB 225

INJECTION POINT N-A

ANALYZED BY WFS, Jr.

SAMPLER N-1

DATE 10/70

SEWER North Trunk - Mobil Oil
Outfall from Monsanto Dept. 254
is also included.


Sample	Sample* Dilution	Absorbance	(LiCl Dilution)	(Avg. Inject. Rate (ml/min.))	$\left(\frac{1 \text{ gal.}}{3785 \text{ ml.}}\right)$	Flow GPM
12-1 AM					0.000264	
1-2	9/21/70		22500	130	"	775
2-3			4250	180	"	200
3-4			36000	186	"	1770
4-5			34000	140	"	1260
5-6			9000	122	"	290
6-7			33000	118	"	1030
7-8			34000	117	"	1050
8-9			6800	119	"	215
9-10			36000	118	"	1720
10-11			34000	108	"	970
11-12			8000	122	"	260
12-1 PM			34000	141	"	1270
1-2			34000	147	"	1320
2-3			7400	164	"	320
3-4			34000	178	"	1600
4-5			36000	180	"	1710
5-6			33000	180	"	1570
6-7			10400	168	"	460
7-8			32000	143	"	1210
8-9			32000	130	"	1100
9-10			36000	149	"	1420
10-11			33000	190	"	1660
11-12			36000	166	"	1500
12-1 AM			37000	184	"	1800
9/22/70					"	
10-11 AM			39000	203	"	1995
11-12			36000	167	"	1590
12-1 PM			32000	183	"	1410
1-2			32000	170	"	1440
2-3			37000	153	"	1500
3-4			46000	170	"	2075
4-5				185	"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.
 **If a sample has been diluted, the calculated flow should be divided by the dilution factor.



18.

Figure I-1
North Trunk Sewer
Mobil Oil Co. Discharge



Note: Discharge from Monsanto Dept. 254 is also included in total flow shown.

Injection Station N-A
Sampler N-1

Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-2

REV: <u>North Trunk</u>		CODE	PRODUCT	TEST OF: <u>Waste Water Discharge</u>	DATE: <u>12/5/70</u>												
PLANT: <u>Mobil Oil</u>		UPPER SPECIFICATION LIMIT		LOWER SPECIFICATION LIMIT	PERIOD COVERED: <u>9/21 - 9/22/70</u>												
NO. UNDER SPEC		NO. OVER SPEC	DISTRIBUTION TYPE	NO. OF CL	DATA: <u>9/21</u>												
			CONTROL LIMIT SCALES (3σ)	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>UCL_L</td> <td>UCL_R</td> <td>UCL_L</td> <td>UCL_R</td> <td>LCL_L</td> <td>LCL_R</td> </tr> <tr> <td>UCL_L</td> <td>UCL_R</td> <td>UCL_L</td> <td>UCL_R</td> <td>LCL_L</td> <td>LCL_R</td> </tr> </table>		UCL _L	UCL _R	UCL _L	UCL _R	LCL _L	LCL _R	UCL _L	UCL _R	UCL _L	UCL _R	LCL _L	LCL _R
UCL _L	UCL _R	UCL _L	UCL _R	LCL _L	LCL _R												
UCL _L	UCL _R	UCL _L	UCL _R	LCL _L	LCL _R												

	TALLY	2	5	5			
X		1	Acc 2	5 + 4	%	OVER	%

2000-2200	1	1	16.7
1800-2000	1	3	5
1600-1800	5	9	15
1400-1600	8	22	36.7
1200-1400	4	34	56.7
1000-1200	3	41	68.5
800-1000	1	45	75
600-800	1	47	78.4
400-600	1	49	81.7
200-400	4	54	90
0-200	1	59	98.4

UCL _L	UCL _R	3 TOTAL	30	UCL _R
LCL _L	LCL _R	4 DOUBLE TOTAL	60	LCL _R
PROC CAPABILITY				

19.

Table I-2.
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background of Concent

JOB 225

INJECTION POINT N-B

ANALYZED BY WFS, Jr.

SAMPLER N-2

DATE 10/70


SEWER North Trunk - Monsanto North Area
24" Sewer (East)

Sample	Sample* Dilution	Absorbance	(LiCl) Dilution	(Avg. Inject. Rate (ml/min.)) ^x	($\frac{1 \text{ gal.}}{3785 \text{ ml.}}$) ^x	Flow GPM
4-5 AM	--		>100000	55	0.000264	>1040
5-6 9/21/70	--		>100000	46	"	>1215
6-7	--		>100000	44	"	>1160
7-8	--		86250	37	"	845
8-9	--		70000	47	"	870
9-10	--		62000	47	"	770
10-11	--		64000	44	"	745
11-12	--		70000	33	"	610
12-1 PM	--		49000	23	"	360
1-2	--		62500	29	"	480
2-3	--		58000	38	"	585
3-4	--		57000	30	"	455
4-5	--		67500	41	"	735
5-6	--		54000	31	"	445
6-7	--		53000	41	"	575
7-8	--		60500	50	"	606
8-9	--		45500	47	"	565
9-10	--		47000	47	"	585
10-11	--		44500	52	"	610
11-12	--		46500	63	"	775
12-1 AM	--		49000	64	"	830
10-1 9/22/70	--		52000	55	"	755
11-12	--		54000	56	"	605
12-1	--		72000	48	"	915
1-2	--		78000	34	"	700
2-3	--		62000	31	"	510
3-4	--		78000	18	"	370
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	
	--				"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.
**If a sample has been diluted, the calculated flow should be divided by the dilution factor.
20.



21.



Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-4

DEPT <i>North Trunk</i>	CODE	PRODUCT <i>Depts. 264, 266, 276</i>	TEST OF <i>Waste Water Discharge</i>	DATE <i>12/5/70</i>
PLANT <i>Monsanto</i>	UPPER SPECIFICATION LIMIT <i>Injection Station N-1</i>	LOWER SPECIFICATION LIMIT <i>Sampler N-2</i>	PERIOD COVERED <i>9/21/70 - 9/22/70</i>	DATA ANALYZED BY <i>[Signature]</i>
% UNDER SPEC	% OVER SPEC	DISTRIBUTION TYPE	CONTROL LIMIT SCALES (3σ)	
I	TALLY	2 5		
X		f Acc 2 5 4		

71200+	1	3	3	5.5
900-1000	1	1	7	3
800-900	III	3	11	0.4
700-800	THL I	6	20	37
600-700	IIII	4	30	55.5
500-600	THH	5	39	72.4
400-500	III	3	47	87
300-400	I	1	51	94.5
200-300	I	1	53	98.2
100-200		0	54	100
0-100		0		

UCL ₁	UCL ₂	3 TOTAL	27	UCL ₃
LCL ₁	LCL ₂	4 DOUBLE TOTAL	54	LCL ₃
PROD. CAPABILITY	225	700 GPM		

22.

Table I-3.
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background of Concent.)

JOB 225

INJECTION POINT N-C

ANALYZED BY W.F.S., Jr.

SAMPLER N-3

DATE 10/70

SEWER North Trunk, Monsanto North 18" Sew
G St. Dept. 268


Sample	Sample* Dilution	Absorbance	(LiCl Dilution)	(Avg. Inject. Rate (ml/min.))	($\frac{1 \text{ gal.}}{3785 \text{ ml.}}$)	Flow GPM
12-1 AM					0.000265	
1-2	9/21/70				"	
2-3			10750	35	"	100
3-4			8700	34	"	78
4-5			5100	40	"	65
5-6			5850	43	"	67
6-7			6175	42	"	69
7-8			6100	37	"	60
8-9			"	34	"	"
9-10			"	36	"	"
10-11			"	45	"	"
11-12			"	62	"	"
12-1 PM			"	44	"	"
1-2			6175	40	"	66
2-3			6600	36	"	63
3-4			6800	39	"	"
4-5			8800	40	"	94
5-6			7500	35	"	70
6-7	3/1		9500	42	"	26
7-8	3/1		9300	52	"	31
8-9	3/1		8400	49	"	27
9-10	3/1		6300	36	"	63
10-11	3/1		5850	66	"	24
11-12	3/1		9600	41	"	26
12-1 AM	3/1		9900	41	"	26
10-11	11/2/70		9600	71	"	44
11-12			6600	68	"	29
12-1 PM			6000	64	"	25
1-2			5600	56	"	20
2-3			4900	47	"	15
3-4			5700	38	"	14
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.
 **If a sample has been diluted, the calculated flow should be divided by the dilution factor.



Figure I-5

North Trunk Sewer
Monsanto North Area
18" Sewer, G Street
Dept. 263



Injection Station N-C
Sampler N-3

24.

Table I-4
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSAR TO BIODIZE SYSTEMS, INC. (no background LiCl Concent.)

JOB 225

INJECTION POINT N-D

ANALYZED BY WFS, Jr.

SAMPLER N-4

DATE 10/70

SEWER North Trunk - Monsento North
24" Sewer (West) Depts. 258, 270

Sample	Sample* Dilution	Absorbance	(LiCl Dilution) x (Avg. Inject. Rate (ml/min.)) x (1 gal. (3785 ml.))	Flow GPM
12-1 AM	---	---	---	0.000264
1-2 9/21/70	---	---	---	---
2-3	---	---	34250	58
3-4	---	---	29000	60
4-5	---	---	31250	59
5-6	---	---	30000	57
6-7	---	---	30750	56
7-8	---	---	31000	54
8-9	---	---	32500	50
9-10	---	---	35000	52
10-11	---	---	33500	56
11-12	---	---	34000	58
12-1 PM	---	---	33500	65
1-2	---	---	31000	62
2-3	---	---	52500	39
3-4	---	---	50000	48
4-5	---	---	41000	50
5-6	---	---	43000	55
6-7	---	---	47000	55
7-8	---	---	60000	48
8-9	---	---	49000	51
9-10	---	---	56500	40
10-11	---	---	66750	38
11-12	---	---	49500	45
12-1 AM	---	---	42750	46
1-2 9/22/70	---	---	48500	46
10-11	---	---	32500	81
11-12	---	---	49500	74
12-1 PM	---	---	37750	67
1-2	---	---	35000	84
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---
	---	---	---	---

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**If a sample has been diluted, the calculated flow should be divided by the dilution factor.



Figure I-6

North Trunk Sewer
Monsanto North Area
24" Sewer (West)

24" Sewer Services
Monsanto Depts.:
258
270

Injection Station N-D
Sampler N-4



26.

Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-7

DEPT North Trunk	CODE	PRODUCT Deots. 258, 270	TEST OF Waste Water Discharge - 24" Sewer (West)	DATE 12/5/70
PLANT Monsanto	JOB SPECIFICATION LIMIT Injection Station N-E	LARGER SPECIFICATION LIMIT Sampler N-4	PERIOD COVERED 9/21/70 - 9/22/70	DATA ANALYST [Signature]
UNDER SPEC	OVER SPEC	DISTRIBUTION TYPE	CONTROL LIMIT SCALES (30)	
			UCL	LCL
I	TALLY	2	5	9
X		1	Acc 2	5.4

BIN	COUNT	PERCENTAGE	UNDER	OVER
900-1001	1	.8		
800-900	0	.0		
700-800	2	1.2		
600-700	7	3.2		
500-600	10	3.6		
400-500	8	85.6		
300-400	0	.0		
200-300	0	.0		
100-200	0	.0		
0-100	0	.0		

UCL	LCL	3 TOTAL	28	UCL
LCL	LCL	4 DOUBLE TOTAL	56	LCL
PROC CAPABILITY				

27.

Table I-5
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEM, INC. (no background Conc.)

JOB 225

INJECTION POINT N-E

ANALYZED BY WFS, Jr.

SAMPLER N-5

DATE 10/70

SEWER North Trunk - Monsanto North Area
18" Sewer (West) Depts 256
258(N)
262
272


Sample	Sample* Dilution	Absorbance	(LiCl Dilution)	(Avg. Inject. Rate (ml/min.))	$\left(\frac{1 \text{ gal.}}{3785 \text{ ml.}}\right)$	Flow* GPM
12-1 AM	—	—	—	—	0.000264	—
1-2 9/21/70	—	—	—	—	—	—
2-3	—	—	—	43	—	—
3-4	—	—	9900	44	—	115
4-5	—	—	13250	46	—	160
5-6	—	—	14500	47	—	180
6-7	—	—	14750	47	—	185
7-8	—	—	13750	47	—	170
8-9	—	—	14500	45	—	170
9-10	—	—	15250	44	—	175
10-11	—	—	16500	42	—	185
11-12	—	—	17000	37	—	165
12-1 PM	—	—	17400	41	—	190
1-2	—	—	18250	49	—	236
2-3	—	—	20000	53	—	280
3-4	—	—	—	47	—	—
4-5	—	—	—	44	—	—
5-6	—	—	26000	44	—	300
6-7	—	—	27500	38	—	275
7-8	—	—	25000	40	—	265
8-9	—	—	17500	36	—	165
9-10	—	—	14400	46	—	175
10-11	—	—	15500	46	—	190
11-12	—	—	16500	46	—	200
12-1 9/22/70	—	—	17750	41	—	190
1-2 AM	—	—	17750	41	—	190
10-11	—	—	13750	44	—	160
11-12	—	—	12000	48	—	150
12-1 PM	—	—	12600	52	—	175
1-2	—	—	12500	54	—	180
2-3	—	—	12750	57	—	160
3-4	—	—	17500	39	—	180

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**If a sample has been diluted, the calculated flow should be divided by the dilution factor.



29.



Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-9

DEPT. 258, 258, 262, 272		CODE North Trunk		PRODUCT Waste Water Discharge - 18" Sewer (West)		TEST OF 12/70	
PLANT Monsanto Injection Station 1-f		UPPER SPECIFICATION LIMIT		PERIOD COVERED 7/21/70 - 9/22/70		DATE 12/70	
SAMPLER N-5		CONTROL LIMIT SCALES (3σ)		LCL ₁ _____		LCL ₂ _____	
DISTRIBUTION TYPE		CONTROL LIMIT SCALES (3σ)		LCL ₁ _____		LCL ₂ _____	
TALLY		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
2 5 6		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
f Acc 2 E + 4		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
30.		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
27.5-300		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
250-275		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
225-250		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
200-225		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
175-200		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
150-175		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
125-150		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
100-125		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
3 TOTAL 26		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	
4 DOUBLE TOTAL 52		PERCENTAGE UNDER		LCL ₁ _____		LCL ₂ _____	
PRIC. CAPABILITY		PERCENTAGE OVER		LCL ₁ _____		LCL ₂ _____	




Table I-6

ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background Li Content)

JOB 225

INJECTION POINT N(A,B,C,D,E)

ANALYZED BY WFS Jr.

SAMPLER N-6

DATE 10/70

SEWER North Trunk- 30" Line to Treat. Ph


Sample	Sample Dilution	Absorbance	(LiCl Dilution) ^x	(Avg. Inject. Rate (ml/min.)) ^x	($\frac{1 \text{ gal.}}{3785 \text{ ml.}}$) ^x	Flow GPM
12-1 AM 9/21/70	-	-	-	-	0.000264	-
1-2	-	-	-	130	"	-
2-3	-	-	92,000	316	"	7850
3-4	-	-	77,000	324	"	6600
4-5	-	-	65,000	340	"	5850
5-6	-	-	65,000	315	"	5910
6-7	-	-	65,000	307	"	5270
7-8	-	-	43,500	292	"	5100
8-9	-	-	44,000	295	"	3400
9-10	-	-	46,500	297	"	3650
10-11	-	-	39,500	295	"	3080
11-12	-	-	37,750	312	"	3115
12-1 PM	-	-	40,000	314	"	3325
1-2	-	-	36,000	327	"	3285
2-3	-	-	45,000	330	"	3730
3-4	-	-	43,000	342	"	2900
4-5	-	-	41,500	355	"	3700
5-6	-	-	45,000	345	"	4110
6-7	-	-	43,000	344	"	3715
7-8	-	-	40,000	333	"	3520
8-9	-	-	40,000	313	"	3315
9-10	-	-	40,000	338	"	3580
10-11	-	-	-	392	"	-
11-12	-	-	-	361	"	-
10-11 AM	-	-	39,000	454	"	4685
11-12 9/22/70	-	-	42,000	404	"	4590
12-1 PM	-	-	39,000	414	"	4275
1-2	-	-	40,000	398	"	4210
2-3	-	-	44,000	278	"	3325
3-4	-	-	68,000	265	"	4770
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**if a sample has been diluted, the calculated flow should be divided by the dilution factor.

31.

Fig. 1



NOTES
 ELEVATIONS SHOWN ARE MEAN SEA LEVEL DATA
 200 SEA LEVEL DATUM TO BE USED FOR ALL DATA
 (WATER & SURFACE) SEE REPORT FOR MONSANTO
 VILLES)

NO. 101		REVISION		DATE	
MONSANTO MOBIOZE SYSTEMS INC. 810 NORTHERN BOULEVARD GREAT NECK, NEW YORK 11021					
Location of Injection and Sampling Stations for 1st Area Measurement Work					
WILLIAM D. GIBBY SENIOR ENGINEER					
DATE	BY	CHECKED	DATE	BY	DATE
11/25/55	W.D.G.	W.D.G.	11/25/55	W.D.G.	11/25/55
NO.	REV.	DATE	BY	DATE	BY
1					



Figure I-10
North Trunk Sewer
30" Line to Treatment Plt.



Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-11

DEPT		CODE	PRODUCT North Trunk Flows after Am. Zinc Shutdown		Waste Water Flow - North Trunk Sewer			DATE 12/15/70
PLANT North Trunk		UPPER SPECIFICATION LIMIT Injection Stations (A, E, F, F)		OVER SPECIFICATION LIMIT Sample Station N-6		PERIOD COVERED 9/21/70 - 9/22/70		DATE ANALYZED BY JLY
UCL _L		UCL _H		LCL _L		LCL _H		
CONTROL LIMIT SCALES (3σ)		UCL _L		UCL _H		LCL _L		LCL _H
I		TALLY		2		5		5
X		f		Acc		2		5.4
								OVER

4800-5000							
4600-4800		2	2	5			
4400-4600		1	5	2.5			
4200-4400		2	8	20			
4000-4200		1	11	17.5			
3800-4000		4	16	40			
3600-3800		1	21	52.5			
3400-3600		2	24	60			
3200-3400		5	31	77.5			
3000-3200		2	38	95			

3.)

UCL _L	UCL _H	3 TOTAL	20	UCL _R				
LCL _L	LCL _H	4 DOUBLE TOTAL	40	LCL _R				
PROC CAPABILITY								
CONTROL LIMIT SCALES (3σ)		UCL _L		UCL _H		LCL _L		LCL _H

Table I-7

ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background) Conc.

JOB 225

INJECTION POINT N-F

ANALYZED BY W.F.S. Jr.

SAMPLER N-7

DATE 10/70

SEWER North Trunk 12" Line from Dept. 254

Sample	Sample* Dilution	Absorbance	(LiCl Dilution) ×	(Avg. Inject. Rate (ml/min.)) ×	($\frac{1 \text{ gal.}}{3785 \text{ ml.}}$) =	Flow* GPM
9-10 AM	—	—	21,500	10	0.000264	57
10-11 9/16/70	—	—	24,500	8	"	52
11-12	—	—	26,000	8	"	35
12-1 PM	—	—	78,000	8	"	165
1-2 9/16/70	—	—	30,500	8	"	65
2-3	—	—	31,000	8	"	66
3-4	—	—	39,500	8	"	84
4-5	—	—	52,500	8	"	110
5-6	—	—	75,000	8	"	160
6-7	—	—	—	8	"	—
7-8	—	—	81,000	8	"	170
8-9	—	—	94,000	8	"	200
9-10 AM	—	—	18,000	15	"	71
10-11 9/17/70	—	—	—	16	"	—
11-12	—	—	—	17	"	—
12-1	—	—	—	18	"	—
1-2	—	—	—	19	"	—
2-3	—	—	45,000	21	"	250
3-4	—	—	11,800	21	"	66
4-5	—	—	13,000	18	"	62
5-6	—	—	14,000	16	"	54
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	


*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**If a sample has been diluted, the calculated flow should be divided by the dilution factor.



35.

Figure T-12
North Trunk Sewer
12" Line from Dept. 254
Monsanto Chem. Co.





37.



Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-14

DEPT 214	CODE	PRODUCT N-8	TEST OF North Trunk Sewer - Waste H₂O	DATE 12/8/70
PLANT Monsanto	UPPER SPECIFICATION LIMIT	LOWER SPECIFICATION LIMIT	PERIOD COVERED 9/16/70 - 9/17/70	DATA ANALYST JLJ
% UNDER SPEC	OVER SPEC	DISTRIBUTION TYPE	CONTROL LIMIT SCALES (3σ)	
I	TALLY	2 5 3	UCL ₁ UCL ₂ UCL ₃ UCL ₄ UCL ₅ UCL ₆ UCL ₇ UCL ₈ UCL ₉ UCL ₁₀ UCL ₁₁ UCL ₁₂ UCL ₁₃ UCL ₁₄ UCL ₁₅ UCL ₁₆ UCL ₁₇ UCL ₁₈ UCL ₁₉ UCL ₂₀ UCL ₂₁ UCL ₂₂ UCL ₂₃ UCL ₂₄ UCL ₂₅ UCL ₂₆ UCL ₂₇ UCL ₂₈ UCL ₂₉ UCL ₃₀ UCL ₃₁ UCL ₃₂ UCL ₃₃ UCL ₃₄ UCL ₃₅ UCL ₃₆ UCL ₃₇ UCL ₃₈ UCL ₃₉ UCL ₄₀ UCL ₄₁ UCL ₄₂ UCL ₄₃ UCL ₄₄ UCL ₄₅ UCL ₄₆ UCL ₄₇ UCL ₄₈ UCL ₄₉ UCL ₅₀ UCL ₅₁ UCL ₅₂ UCL ₅₃ UCL ₅₄ UCL ₅₅ UCL ₅₆ UCL ₅₇ UCL ₅₈ UCL ₅₉ UCL ₆₀ UCL ₆₁ UCL ₆₂ UCL ₆₃ UCL ₆₄ UCL ₆₅ UCL ₆₆ UCL ₆₇ UCL ₆₈ UCL ₆₉ UCL ₇₀ UCL ₇₁ UCL ₇₂ UCL ₇₃ UCL ₇₄ UCL ₇₅ UCL ₇₆ UCL ₇₇ UCL ₇₈ UCL ₇₉ UCL ₈₀ UCL ₈₁ UCL ₈₂ UCL ₈₃ UCL ₈₄ UCL ₈₅ UCL ₈₆ UCL ₈₇ UCL ₈₈ UCL ₈₉ UCL ₉₀ UCL ₉₁ UCL ₉₂ UCL ₉₃ UCL ₉₄ UCL ₉₅ UCL ₉₆ UCL ₉₇ UCL ₉₈ UCL ₉₉ UCL ₁₀₀	
X	1 Acc 2 5 4			

220-240			
200-220	II	3	3
180-200	III	5	11
160-180	I	1	17
140-160	III	6	24
120-140	III	5	35
100-120	II	2	42
80-100	III	3	47
60-80	III	5	55
40-60		0	60
20-40			
0-20			

UCL ₁	UCL ₂	3 TOTAL	30	UCL ₃
LCL ₁	LCL ₂	4 DOUBLE TOTAL	60	LCL ₃
PROC CAPABILITY				

38.

Table I-9
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background of Concent

JOB 253

INJECTION POINT N-H

ANALYZED BY gm

SAMPLER N-9

DATE 12/7 & 12/8/70

SEWER 27" Sewer (East) American Zinc
Discharge to North Trunk

Sample	Sample* Dilution	Absorbance	(LiCl Dilution)	(Avg. Inject. Rate (ml/min))	($\frac{1 \text{ gal.}}{3785 \text{ ml.}}$)	Flow GPI	
PM 1	9:30-10:30	-	0.040	60000	191	0.000264	2300
2	12/7/70	-	0.047	52000	189	"	2600
3	"	-	0.040	60000	188	"	2980
4	"	-	0.037	65000	189	"	3245
5	"	-	0.042	58000	191	"	2925
6	"	-	0.047	52000	192	"	2636
7	"	-	0.040	60000	191	"	3025
8	"	-	0.043	56000	189	"	2793
9	"	-	0.040	60000	189	"	2994
10	"	-	0.045	54000	187	"	2666
11	"	-	0.050	49000	179	"	2316
12	"	-	0.045	54000	169	"	2409
13	"	-	0.040	60000	163	"	2562
14	"	-	0.038	64000	175	"	2959
15	"	-	0.045	57000	186	"	2800
16	"	-	0.045	57000	179	"	2690
17	"	-	0.040	64000	162	"	3211
18	"	-	0.043	113000	28	"	3820
19	"	-	0.043	59000	170	"	2650
20	"	-	0.043	59000	168	"	2620
21	"	-	0.042	61000	169	"	2720
22	"	-	0.041	62000	171	"	2620
23	"	-	0.040	64000	171	"	2610
24	"	-	0.056	45000	170	"	2020

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**If a sample has been diluted, the calculated flow should be divided by the dilution factor.



Figure T-15
North Trunk Sewer
American Zinc Discharge
27" East Sewer

Injector Station N-4
Sample Station N-9




Table I-10
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background) 1% Concent

JOB 253

INJECTION POINT N-I

ANALYZED BY JM

SAMPLER N-10

DATE 12/7 & 12/8/70

SEWER 21" West Sewer - American Zinc
Discharge to North Trunk

Sample	Sample* Dilution	Absorbance	(LiCl Dilution) ×	(Avg. Inject. Rate (ml/min)) ×	(1 gal. 3785 ml.)	Flow GPI
PM 1 9:30-10:30	—	0.230	11250	19	0.000267	57
2 12/7/70	—	0.145	17500	19	"	88
3	—	0.055	44500	18	"	211
4	—	0.067	37000	18	"	176
5	—	0.064	38500	18	"	183
6	—	0.062	39500	18	"	188
7	—	0.085	29500	"	"	140
8	—	0.057	43000	"	"	204
9	—	0.076	32000	"	"	157
10	—	0.060	41000	"	"	195
11	—	0.060	41000	"	"	195
12	—	0.063	39000	"	"	185
13	—	0.063	39000	"	"	185
14	—	0.054	45000	"	"	214
15	—	0.072	31500	"	"	150
16	—	0.053	48000	"	"	228
17	—	0.040	62000	"	"	295
18	—	0.038	66000	"	"	314
19	—	0.042	60000	"	"	285
20	—	0.047	57000	"	"	271
21	—	0.042	60000	"	"	285
22	—	0.043	59000	"	"	280
23	—	0.043	59000	"	"	280
24	—	0.042	60000	"	"	285

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**If a sample has been diluted, the calculated flow should be divided by the dilution factor.




Figure I-16

North Trunk Sewer
American Zinc Discharge
21" West Sewer

Injection Station N-I
Sample Station N-10

• 24



9:50 10:50 PM
12/7/70

Sample Number (11 Sample/Hr)

Mo. anto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. I-17

Plant North Trunk	ECODE	PRODUCT	TEST OF Waste Water Flow-American Zinc (Total)	DATE 12/16/70																																																																																																									
UPPER SPECIFICATION LIMIT American Zinc	SPECIFICATION LIMIT Injection Stations HQT	LOWER SPECIFICATION LIMIT Samplers N-7 & N-10	PERIOD COVERED 12/7/70 & 12/8/70	DATA ANALYZED BY [Signature]																																																																																																									
<p>CONTROL LIMIT SCALES (3σ)</p> <p>UCL₁ _____ UCL₂ _____ UCL₃ _____ LCL₁ _____ LCL₂ _____ LCL₃ _____</p>																																																																																																													
1	2	5	6																																																																																																										
X	TALLY	f	Acc. 2	5 + 4																																																																																																									
<p>PERCENTAGE OVER</p> <p>UCL₁ _____ UCL₂ _____ UCL₃ _____ LCL₁ _____ LCL₂ _____ LCL₃ _____</p>																																																																																																													
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:15%;">4000-4200</td> <td style="width:10%;">1</td> <td style="width:10%;">1</td> <td style="width:10%;">2.1</td> <td style="width:55%;"></td> </tr> <tr> <td>3800-4000</td> <td>0</td> <td>2</td> <td>4.1</td> <td></td> </tr> <tr> <td>3600-3800</td> <td>0</td> <td>2</td> <td>4.1</td> <td></td> </tr> <tr> <td>3400-3600</td> <td>1</td> <td>3</td> <td>6.1</td> <td></td> </tr> <tr> <td>3200-3400</td> <td>0</td> <td>4</td> <td>8.1</td> <td></td> </tr> <tr> <td>3000-3200</td> <td>9</td> <td>13</td> <td>21</td> <td></td> </tr> <tr> <td>2800-3000</td> <td>7</td> <td>29</td> <td>60.4</td> <td></td> </tr> <tr> <td>2600-2800</td> <td>2</td> <td>38</td> <td>79.2</td> <td></td> </tr> <tr> <td>2400-2600</td> <td>2</td> <td>42</td> <td>87.5</td> <td></td> </tr> <tr> <td>2200-2400</td> <td>2</td> <td>46</td> <td>96</td> <td></td> </tr> <tr> <td>2000-2200</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1800-2000</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1600-1800</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1400-1600</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1200-1400</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1000-1200</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>800-1000</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>600-800</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>400-600</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>200-400</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>0-200</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>					4000-4200	1	1	2.1		3800-4000	0	2	4.1		3600-3800	0	2	4.1		3400-3600	1	3	6.1		3200-3400	0	4	8.1		3000-3200	9	13	21		2800-3000	7	29	60.4		2600-2800	2	38	79.2		2400-2600	2	42	87.5		2200-2400	2	46	96		2000-2200					1800-2000					1600-1800					1400-1600					1200-1400					1000-1200					800-1000					600-800					400-600					200-400					0-200				
4000-4200	1	1	2.1																																																																																																										
3800-4000	0	2	4.1																																																																																																										
3600-3800	0	2	4.1																																																																																																										
3400-3600	1	3	6.1																																																																																																										
3200-3400	0	4	8.1																																																																																																										
3000-3200	9	13	21																																																																																																										
2800-3000	7	29	60.4																																																																																																										
2600-2800	2	38	79.2																																																																																																										
2400-2600	2	42	87.5																																																																																																										
2200-2400	2	46	96																																																																																																										
2000-2200																																																																																																													
1800-2000																																																																																																													
1600-1800																																																																																																													
1400-1600																																																																																																													
1200-1400																																																																																																													
1000-1200																																																																																																													
800-1000																																																																																																													
600-800																																																																																																													
400-600																																																																																																													
200-400																																																																																																													
0-200																																																																																																													
<p>UCL₁ _____ UCL₂ _____ UCL₃ _____ LCL₁ _____ LCL₂ _____ LCL₃ _____</p> <p>CONTROL LIMIT SCALES (3σ)</p> <p>UCL₁ _____ UCL₂ _____ UCL₃ _____ LCL₁ _____ LCL₂ _____ LCL₃ _____</p>																																																																																																													

43.

APPENDIX II

VILLAGE OF SAUGET
SOUTH TRUNK SEWER
FLOW DATA AND DATA ANALYSIS

Table II-1

ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSIEUR TO BIODIZE SYSTEMS, INC. (no background salt Concent.)

JOB 225

INJECTION POINT S-A

ANALYZED BY WFS, Jr.

SAMPLER S-1

DATE 10/70

SEWER South Trunk- 8" Sterling Steel Discha

Sample	Sample* Dilution	Absorbance	(LiCl Dilution) x	(Avg. Inject. Rate (nl/min)) x	(1 gal. 3785 ml.) =	Flow* GPM
12-1 PM			5500	66	0.000266	96
1-2 9/25/70			9800	51	"	130
2-3			7600	40	"	80
3-4			8600	35	"	80
4-5			9600	50	"	125
5-6			8900	66	"	155
6-7			"	"	"	"
7-8			"	"	"	"
8-9			"	"	"	"
9-10			"	"	"	"
12-1 AM	3/1		5500	42	"	15
8-9 9/24/70	1/1		8800	54	"	62
					"	
					"	
1-2 PM	9/1		7400	27	"	5
2-3 10/13/70	"		13000	64	"	22
3-4	"		12000	41	"	13
4-5	"		10000	25	"	12
5-6	"		6400	72	"	12
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.
 **If a sample has been diluted, the calculated flow should be divided by the dilution factor.

44.

Table II-2
ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEM, INC. (no background Concent.)

JOB 225

INJECTION POINT S-A

ANALYZED BY WFS, Jr.

SAMPLER S-2

DATE 10/70

SEWER South Trunk - Village Sewers
(a) 8" x 12" Sewers - Little Ave.
(b) 12" Sewer - Falling Springs Ave.
(c) Sterling Steel

Sample	Sample* Dilution	Absorbance	(LiCl Dilution)	(Avg. Inject. Rate (ml/min.))	$\left(\frac{1 \text{ gal.}}{3785 \text{ ml.}}\right)$	Flow GPM
12-1 PM	-		8100	66	0.000264	140
1-2 9/25/70	-		8200	51	"	110
2-3	-		8500	40	"	90
3-4	-		9500	35	"	88
4-5	-		16000	30	"	210
8-9	-		14000	46	"	170
9-10	3/1		5500	42	"	15
10-11	7/1		10000	38	"	12
12-1 AM	15/1		4200	42	"	3
1-2 9/26/70	7/1		6200	34	"	7
2-3	3/1		5250	42	"	14
3-4	"		11400	53	"	39
4-5	"		12750	50	"	45
5-6	"		9600	56	"	35
6-7	"		10600	57	"	39
7-8	7/1		5400	54	"	10
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.
**If a sample has been diluted, the calculated flow should be divided by the dilution factor.



Figure I-

South Trunk Sewer
Sterling Steel & Village

Note: Two air conditioning units
at Sterling Steel use well
water as the cooling agent.
Max Temp 9/25/70 85°F A.C. operating
Max Temp 10/12/70 62°F A.C. not operating

Injection Station S-A

Sample Stations S-1 & S-2

X 8" Sterling Steel
Sewer

o Total Village Flow

- (a) 8" & 12" Sewers - Little Ave
- (b) 12" Sewer - Falling Spr. Ave.
- (c) 8" Sterling Steel Sewer

Flow Rate (Gal./Min.)

220
200
180
160
140
120
100
80
60
40
20

Noon

9/25/70

9/26/70

Noon

10/12/70

Time

Minimum Temp. 9/25/70 56°F
Assumed that A.C. units
at Sterling Steel
Shutdown

A.C. at Sterling not operating

94




Table II-3

ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background Concent.)

JOB 225

INJECTION POINT S-B

ANALYZED BY W.F.S. Jr.

SAMPLER S-3

DATE 10/70


SEWER South Trunk - 36" Sewer
Corner 5th St. & Falling Springs Rd.

Sample	Sample* Dilution	Absorbance	(LiCl Dilution) x	(Avg. Inject. Rate (ml/min)) x	(1 gal. 3785 ml.) =	Flow GPM
1-2 PM	—		29500	278	0.000264	2165
2-3 9/25/70	—		26000	295	"	2030
3-4	—		28500	322	"	2425
4-5	—		31250	347	"	2870
5-6	—		35000	347	"	3215
6-7	—		34500	334	"	3050
7-8	—		34250	313	"	2840
8-9	—		37750	286	"	2760
9-10	—		42500	267	"	3070
10-11	—		41500	255	"	2800
11-12	—		39500	240	"	2510
12-1 AM	—		41000	230	"	2490
1-2 9/26/70	—		36500	230	"	2220
2-3	—		38250	230	"	2330
3-4	—		43500	230	"	2640
4-5	—		43500	229	"	2630
5-6	—		37000	225	"	2200
					"	"
10-11 AM	—		45000	213	"	2540
11-12 9/26/70	—		45000	220	"	2620
12-1 PM	—		48000	220	"	2790
1-2	—		46000	220	"	2790
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"
					"	"

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.
 **If a sample has been diluted, the calculated flow should be divided by the dilution factor.



• 87



Monsanto

QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. II-3

Plant Monsanto		Code		Product		Test of Waste Water Discharge - 36" Sewer into 24"		Date 12/13/70	
Factory South Trunk Injection Station S-B		Upper Specification Limit		Lower Specification Limit		Period Covered 9/25/70-9/26/70		Data by JL	
Location 5th St. & Falling Springs Rd.		Distribution Type		Control Limit Scales (3σ)		Control Limit Scales (3σ)		Control Limit Scales (3σ)	
TALLY		2 5		3		PERCENTAGE		OVER	
X		f		Acc. 2 5 4		UNDER		OVER	
3200-3300		1		1		.4			
3100-3200		0		2		.76			
3000-3100		2		4		1.5			
2900-3000		0		6		4.3			
2800-2900		2		8		9			
2700-2800		4		14		3.4			
2600-2700		2		20		7.6			
2500-2600		3		25		59.5			
2400-2500		2		30		71.5			
2300-2400		1		33		78.5			
2200-2300		1		35		83.4			
2100-2200		2		38		90.5			
2000-2100		1		41		97.5			
3 TOTAL		21		UCL _R					
4 SAMPLE TOTAL		42		LCL _R					
PROD. CAPABILITY		300		2600		CONTROL LIMIT SCALES (3σ)			

54




Table II-4

ANALYTICAL DATA SHEET

FOR

SALT DILUTION FLOW MEASUREMENT METHOD

MONSANTO BIODIZE SYSTEMS, INC. (no background) Concent

JOB 225

INJECTION POINT S-C

ANALYZED BY WFS, Jr.

SAMPLER S-4

DATE 10/70

SEWER South Trunk - Cerro
Dead Creek Outlet


Sample	Sample* Dilution	Absorbance	(LiCl) (Dilution)	(Avg. Inject. Rate (ml/min))	$\left(\frac{1 \text{ gal.}}{3785 \text{ ml.}} \right)$	Flow GPA
12-1 PM	—		18000	230	0.000267	1950
1-2 9/25/70	—		18000	260	"	1250
2-3	—		36500	230	"	2150
3-4	—		34000	157	"	1400
4-5	—		34000	158	"	1400
5-6	—		30000	158	"	1250
6-7	—		35000	157	"	1450
7-8	—		37000	156	"	1550
8-9	—		37000	157	"	1550
9-10	—		35000	156	"	1450
10-11	—		34000	156	"	1450
11-12	—		35000	152	"	1400
12-1 AM	—		34000	148	"	1350
1-2 9/26/70	—		34000	147	"	1350
2-3	—		36500	153	"	1500
3-4	—		35000	155	"	1450
4-5	—		27000	143	"	1400
5-6	—		50000	120	"	1600
6-7	—		38000	122	"	1250
7-8	—		36500	127	"	1250
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	
					"	

*Sample dilution necessary at times to get salt concentration to fall within bounds of the calibration curve.

**If a sample has been diluted, the calculated flow should be divided by the dilution factor.



51.



Monsanto


QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. II-5

DEPT: Cerro Copper CODE: PRODUCT: TEST OF: Waste Water Flow - Cerro-Dead Creek Outlet DATE: 12/13/70
 PLANT: South Trunk Injection Station S-C Sample Station S-4 PERIOD COVERED: 9/25/70 - 9/26/70
 L. UNDER SPEC: OVER SPEC: DISTRIBUTION TYPE: FOR CCI: CONTROL LIMIT SCALES (3σ): UCL₁ UCL₂ UCL₃ UCL₄ LCL₁ LCL₂ LCL₃ LCL₄

TALLY	2		5		6	
	f	Acc	2	5	4	OVER
>1650			2	2	5	
1550-1600	1		5		2.5	
1500-1550	2		8		20	
1450-1500	1		11		27.5	
>1400-1450	4		16		40	
1350-1400	4		24		60	
1300-1350	2		30		75	
1250-1300	0		32		80	
1200-1250	4		36		90	
1150-1200	0		40		100	
UCL ₁	UCL ₂	3 TOTAL	20	UCL ₃		
LCL ₁	LCL ₂	4 DOUBLE TOTAL	40	LCL ₃		
PART CAPABILITY	±150		1400			



52.




Figure II-6
 24" South Trunk Sewer
 Monsanto Chemical Co. Property

Injection Stations S(A,B,C)
 Sample Station S-5

Sources:

(a) Flow from Junction Box at North End of Dead Creek

(b) Flow from 15" Village Sewer which includes Sterling Steel, Little's Subdivision & Monsanto Heights Subdivision

(c) 36" Sewer at Corner of 5th St. & Falling Springs Road - Monsanto Depts. Included are:

222	243	360
226	244	384
230	245	409
231	246	513
232	247	705
233	248	851
234	273	837
239	350	

(d) 18" Sewer Dept. 250
 (e) 15" Sewer Dept. 251

McSanto


QUALITY CONTROL

FREQUENCY DISTRIBUTION ANALYSIS SHEET

Fig. II-7


DEPT	CODE	PRODUCT	TEST OF	DATE
		S-5	South Trunk 24" Sewer Flow	
PLANT	UPPER SPECIFICATION LIMIT	LOWER SPECIFICATION LIMIT	PERIOD COVERED	DATA ANALYZED BY
South Trunk			9/25/70 - 9/26/70	
% UNDER SPEC	% OVER SPEC	DISTRIBUTION TYPE	CONTROL LIMIT SCALES (3σ)	
I		2	UCL ₁ 12 10 9 8 7 6 5 4 3 2 1 0 1 2 3 4 5 6 7 8 9 10 12	
X	TALLY	f	5	6
		Acc. 2	PERCENTAGE OVER	
		5 + 4	LCL ₁ 12 10 9 8 7 6 5 4 3 2 1 0 1 2 3 4 5 6 7 8 9 10 12	
			LCL ₂ 12 10 9 8 7 6 5 4 3 2 1 0 1 2 3 4 5 6 7 8 9 10 12	
5600-5700		1	1	2.5
5500-5600		1	3	7.5
5400-5500		2	6	15
5300-5400		1	9	22.5
5200-5300		2	12	30
5100-5200		5	19	47.5
5000-5100		3	27	67.5
4900-5000		1	31	77.5
4800-4900		0	32	80
4700-4800		2	34	85
4600-4700		2	38	95
JCL ₁	UCL ₁	3 TOTAL	20	UCL ₂
LCL ₁	LCL ₁	4 DOUBLE TOTAL	40	LCL ₂
PROC. CAPABILITY				
				CONTROL LIMIT SCALES (3σ)
				UCL ₁ 12 10 9 8 7 6 5 4 3 2 1 0 1 2 3 4 5 6 7 8 9 10 12

55.





57.



APPENDIX III

VILLAGE OF SAUGET

WEST TRUNK SEWER

FLOW DATA AND DATA ANALYSIS



09



Figure 11-1


West Trunk Sewer
Cerro Copper Discharge

Injection Station S-D
Injection Station S-B

X 18' Sewer from Metal
Receiving Oil & Staff
Furnace Bldg. No. 19
24" West Discharge
(Includes Discharge
from 13" Sewer X)
Total Discharge to
West Trunk Sewer



• 719



APPENDIX IV

AVERAGE WASTE WATER FLOWS
AT VILLAGE OF SAUGET SAMPLE STATIONS

FLOW CALCULATIONS FOR INDIVIDUAL CONTRIBUTORS

TABLE # IV-1

VILLAGE OF SAUGET SEWER SYSTEM

AVERAGE WASTE WATER FLOWS

<u>Sample Station</u>	<u>Village Sewer</u>	<u>Avg. Flow (gpm)</u>	<u>Dates Measured</u>	<u>Sources</u>
N-1	North Trunk	1,250	9/21 & 9/22/70	Mobil Oil + Monsanto 12" Sewer from Dept. 254
		10	12/70	Mobil Oil
N-2	North Trunk	700	9/21 & 9/22/70	Monsanto North Area - 24" East Sewer - Depts. 264, 266, 276
N-3	North Trunk	50	" "	Monsanto North Area - 18" Sewer G St. Dept. 268
N-4	North Trunk	590	" "	Monsanto North Area - 21" West Sewer - Depts. 258, 270
N-5	North Trunk	190	" "	Monsanto North Area - 18" West Sewer - Depts. 256, 258, 262, 272
N-6	North Trunk	3,800	" "	North Trunk - 30" Sewer to Treatment Plant - Average flow after American Zinc shut down during measurement run.
N-7	North Trunk	110	9/16 & 9/17/70	Monsanto Main Plant - 12" Sewer from Dept. 254
N-8	North Trunk	140	" "	Monsanto Main Plant - 18" Sewer from Dept. 214

TABLE #IV-1(continued)

VILLAGE OF SAUGET SEWER SYSTEM
AVERAGE WASTE WATER FLOWS

<u>Sample Station</u>	<u>Village Sewer</u>	<u>Avg. Flow (gpm)</u>	<u>Dates Measured</u>	<u>Sources</u>
N-9	North Trunk	2,760	12/7 & 12/8/70	American Zinc 27" East Sewer
N-10	North Trunk	210	" "	American Zinc 21" West Sewer
-	North Trunk	50	12/16/70	American Zinc Sanitary Sewer (Grab Sample)
S-1	South Trunk	110	9/25 & 9/26/70 10/12/70	Sterling Steel Casting Co. - 8" Sewer - Air Conditioning Units oper.
	South Trunk	20	9/25/ & 9/26/70	Sterling Steel Casting Co.-A/C shutdown
S-2	South Trunk	140	9/25/70 & 9/26	Village Sewers + Sterling Steel Casting Co. -Sterling Steel Air Conditioning units operating
	South Trunk	50		Village Sewer + Sterling Steel Casting Co. - Sterling Steel Air Conditioning Units not operating
S-3	South Trunk	2,620	9/25 & 9/26/70	Monsanto Main Plant - 36" Sewer Monsanto Depts 222, 226, 230, 231, 232, 233, 234, 239, 243, 244, 245, 246, 247, 248, 273, 350, 360, 384, 409, 512, 705, 831, 832
S-4	South Trunk	1,470	9/25 & 9/26/70	Cerro Copper & Brass Co. discharge at North End of Dead Creek
S-5	South Trunk	5,150	" "	Monsanto Main Plant - 24" Sewer-5th St.

TABLE #IV-1(continued)

VILLAGE OF SAUCET SEWER SYSTEM
AVERAGE WASTE WATER FLOWS

<u>Sample Station</u>	<u>Village Sewer</u>	<u>Avg. Flow (gpm)</u>	<u>Dates Measured</u>	<u>Sources</u>
S-5(continued)				(a) Cerro Copper & Brass Co. Dead Creek Discharge(S-4) (b) Village Sewers + Sterling Steel Casting Co. (S-2) (c) Monsanto Main Plant - 36" Sewer (S-3) (d) Monsanto Sewers - 18" Sewer Dept. 251 - 18" Sewer Dept.250
67. S-6	South Trunk	4,950	9/25 & 9/26/70 10/12/70	Monsanto Main Plant - 30" Sewer 5th St., Monsanto Depts. 210, 221, 223, 233, 236, 255, 257, 263, 810, 811, 831, 902
S-7		175	9/25 & 9/26/70	Cerro Copper & Brass Co.-Bldg #19 Discharges into sewer outlet to West Trunk
S-8	West Trunk	330	9/25/ & 9/26/70	Cerro Copper & Brass Co. - Total Discharge to West Trunk Sewer
W-1	West Trunk	800	12/7 & 12/8/70	Midwest Rubber Company - Discharge to (24" West) Sewer
W-2	West Trunk	965	12/7 & 12/8/70	Midwest Rubber Company - Discharge to (21"East) Sewer

FLOW CALCULATIONS

American Zinc Company

$$FAZ = FN-9 + FN-10 + F_{Sanitary}$$

$$FAZ = 2,760 \text{ gpm} + 210 \text{ gpm} + 50 \text{ gpm}$$

$$FAZ = 3,020 \text{ gpm}$$

Cerro Copper and Brass Company

$$F_{CC\&B} = FS-4 + FS-8$$

$$F_{CC\&B} = 1,470 \text{ gpm} + 330 \text{ gpm}$$

$$F_{CC\&B} = 1,800 \text{ gpm}$$

Mobil Oil Refinery

$$F_{MO} = 10 \text{ gpm}$$

Monsanto Company

(North Area)

$$F_{M-NA} = FN-2 + FN-3 + FN-4 + FN-5$$

$$F_{M-NA} = 700 \text{ gpm} + 50 \text{ gpm} + 590 \text{ gpm} + 190 \text{ gpm}$$

$$F_{M-NA} = 1,530 \text{ gpm}$$

(Main Plant)

$$FS-5 = FS-2 + FS-3 + FS-4 + F(\text{Monsanto 18" sewers Depts. 250 \& 251})$$

$$F_{M(250 \& 251)} = FS-5 - FS-2 - FS-3 - FS-4$$

$$F_{M(250 \& 251)} = 5,150 \text{ gpm} - 65 \text{ gpm} - 2,620 \text{ gpm} - 1,470 \text{ gpm}$$

$$F_{M(250 \& 251)} = 965 \text{ gpm}$$

(Main Plant)

$$F_{M(M-P)} = FS-3 + FS-6 + F_{M(250 \& 251)} + FN-7 + FN-8$$

$$F_{M(M-P)} = 2,620 \text{ gpm} + 4,950 \text{ gpm} + 965 \text{ gpm} + 110 \text{ gpm} + 140 \text{ gpm}$$

$$F_{M(M-P)} = 8,705 \text{ gpm}$$

FLOW CALCULATIONS (continued)

Monsanto Company

(Total)

$$F_{\text{Monsanto}} = F_{\text{M(NA)}} + F_{\text{M(MP)}}$$

$$F_{\text{Monsanto}} = 1,530 \text{ gpm} + 8,785 \text{ gpm}$$

$$F_{\text{Monsanto}} = 10,315 \text{ gpm}$$

Midwest Rubber Company

$$F_{\text{MR}} = F_{\text{W-1}} + F_{\text{W-2}}$$

$$F_{\text{MR}} = 800 \text{ gpm} + 965 \text{ gpm}$$

$$F_{\text{MR}} = 1,765 \text{ gpm}$$

Sterling Steel Casting Company

$$F_{\text{SSC}} = F_{\text{S-1}} \left(\frac{\text{Air Conditioning Units Operating (4 months)}}{(12 \text{ months})} + \right.$$

$$\left. F_{\text{S-1}} \left(\frac{\text{Air Conditioning Units not operating (8 months)}}{(12 \text{ months})} \right) \right)$$

$$F_{\text{SSC}} = 110 \text{ gpm (0.33)} + 20 \text{ gpm (0.67)}$$

$$F_{\text{SSC}} = 36.4 \text{ gpm} + 13.4 \text{ gpm}$$

$$F_{\text{SSC}} = 50 \text{ gpm} *$$

Village of Sauget

$$F_{\text{VS}} = F_{\text{S-2}} - F_{\text{S-1}}$$

$$F_{\text{VS}} = 50 \text{ gpm} - 20 \text{ gpm}$$

$$F_{\text{VS}} = 30 \text{ gpm}$$

*Note: FSSC = 65 gpm was used in calculation of Monsanto Company flow because of operation of air conditioning units during flow test.

APPENDIX V

AVERAGE SUSPENDED SOLIDS CONCENTRATIONS
AT VILLAGE OF SAUCET SAMPLE STATIONS
SUSPENDED SOLIDS CALCULATIONS FOR
INDIVIDUAL CONTRIBUTORS

TABLE # V-1

SUSPENDED SOLIDS DATA

Sample Station	Suspended Solids Concentrations (mg/l)	
	24 Hr. Composite	4 Hr. Composite
N-1	2,084	2,685
N-2	221	227
N-3	126	813
N-4	96	140
N-5	261	240
N-6	885	-
N-7	73	112
N-8	13	10
N-9	59	-
N-10	43	-
S-1	126	-
S-2	423	-
S-3	60	75
S-4	284	-
S-5	293	68
S-6	40	25
S-7	-	-
S-8	71	81
W-1	63	-
W-2	171	-
(W-1 & W-2)	25	41 (Grab Samples)
American Zinc-Sanitary	163 (Grab Sample)	-
Mobil Oil	54 (Grab Sample)	-

TABLE # V-2
 VILLAGE OF SAUGET SEWER SYSTEM
 SUSPENDED SOLIDS

<u>Sample Stations</u>	<u>Village Sewer</u>	<u>Avg. Flow (gpm)</u>	<u>Suspended Solids Conc. (mg/l)</u>	<u>Lbs. Solids per day</u>
N-1	North Trunk	10	54	7
N-2	"	700	221	1,860
N-3	"	50	500	300
N-4	"	590	96	680
N-5	"	190	261	600
N-7	"	110	72	100
N-8	"	140	13	22
N-9	"	2,760	59	1,950
N-10	"	210	43	110
-	"	50	163	100
S-1	South Trunk	50	126	75
S-2	"	80	423	405
S-3	"	2,620	60	1,885
S-4	"	1,470	284	5,000
S-5	"	5,150	293	18,100
S-6	"	4,950	40	2,400
S-8	"	330	71	280
W-1	West Trunk	800	63	600
W-2	"	965	171	1,650

SOLIDS CALCULATIONS

American Zinc Company

$$SS_{AZ} = SS_{N-9} + SS_{N-10} + SS_{Sanitary}$$

$$SS_{AZ} = 1,950 \text{ lbs/day} + 110 \text{ lbs/day} = 100 \text{ lbs/day}$$

$$SS_{AZ} = 2,160 \text{ lbs/day}$$

Cerro Copper & Brass Company

$$SS_{CC\&B} = SS_{S-4} + SS_{S-8}$$

$$SS_{CC\&B} = 5,000 \text{ lbs/day} + 280 \text{ lbs/day}$$

$$SS_{CC\&B} = 5,280 \text{ lbs/day}$$

Mobil Oil Refinery

$$SS_{MO} = 7 \text{ lbs/day}$$

Monsanto Company

(North Area)

$$SS_{M-NA} = SS_{N-2} + SS_{N-3} + SS_{N-4} + SS_{N-5}$$

$$SS_{M-NA} = (1,860 + 300 + 680 + 600) \text{ lbs/day}$$

$$SS_{M-NA} = 3,440 \text{ lbs/day}$$

(Main Plant)

$$SS_{S-5} = SS_{S-2} + SS_{S-3} + SS_{S-4} + SS(\text{Monsanto 18" Sewers Depts. 250 \& 251})$$

$$SS_{M(250 \& 251)} = SS_{S-5} - SS_{S-2} - SS_{S-3} - SS_{S-4}$$

$$SS_{M(250 \& 251)} = (18,100 - 405 - 1,885 - 5,000)$$

$$SS_{M(250 \& 251)} = 10,810$$

$$SS_{(M-MP)} = SS_{S-3} + SS_{S-6} + SS_{M(250 \& 251)} + SS_{N-7} + SS_{N-8}$$

$$SS_{(M-MP)} = (1,885 + 2,400 + 10,810 + 100 + 22) \text{ lbs/day}$$

$$SS_{(M-MP)} = 15,217 \text{ lbs/day}$$

SOLIDS CALCULATIONS (continued)
Monsanto Company (continued)

(Total)

$$SS_{\text{Monsanto}} = SS_{\text{M-NA}} + SS_{\text{M-MP}}$$

$$SS_{\text{Monsanto}} = 3,440 \text{ lbs/day} + 15,217 \text{ lbs/day}$$

$$SS_{\text{Monsanto}} = 18,657 \text{ lbs/day}$$

Midwest Rubber Company

$$SS_{\text{MR}} = SS_{\text{W-1}} + SS_{\text{W-2}}$$

$$SS_{\text{MR}} = (600 + 1650) \text{ lbs/day}$$

$$SS_{\text{MR}} = 2250 \text{ lbs/day}$$

Sterling Steel Casting Company

$$SS_{\text{SSC}} = 75 \text{ lbs/day}$$

Village of Sauget

$$SS_{\text{VS}} = 330 \text{ lbs/day}$$

APPENDIX VI

RESULTS OF METCALF & EDDY WASTE
CHARACTERIZATION AND OPERATING COST DISTRIBUTION
FOR VILLAGE OF SAUGET TREATMENT PLANT

Waste Quantities

The estimated quantities of flow and suspended solids as agreed upon at the August 17th meeting and which are to be used as a basis in determining annual charges are listed in Table 1.

Table 1. Estimated Quantities of
Waste Materials to be Treated

Industry	Operation* days/year	Flow		Suspended Solids	
		Avg. Daily, mgd.	Total Annual, mil.gal.	Avg. Daily, tons/ day	Total Annual Tons
Monsanto Chemical Co.	365	15.6	5,694	6.0	2,190
Exxon Oil Co.	365	1.5	548	2.0	730
American Zinc Co.	365	5.42	1,978	1.3	474
Cerro Copper & Brass Co.	325	1.6	520	0.8	260
Midwest Rubber Co.	273	2.0	546	5.0	1,365
Darling Fertilizer Co.	260	0.04	10	0.09	23
Others	365	0.15	55	0.05	22
TOTALS		26.31	9,351	15.25	5,064

*Based on operating schedule as indicated on Page 18 of Metcalf & Eddy Report dated March 16, 1965 to the Village of Monsanto, Illinois on "Costs for Waste Water Treatment".

Table 2. Estimated Annual Operating and Maintenance Costs

Annual Cost	Plan I			Plan II						
	With Existing Pumping Station Costs	Without Existing Pumping Station Costs		With Existing Pumping Station Costs	Without Existing Pumping Station Costs					
	Total Amount	Flow %	Amount	Susp. Solids %	Amount	Total Amount	Flow %	Amount	Susp. Solids %	Amount
Salaries	\$ 32,000	70.0	\$22,400	30.0	\$ 9,600	\$32,000	70.0	\$22,400	30.0	\$ 9,600
Power and Fuel	35,000	90.0	31,500	10.0	3,500	5,000	30.0	1,500	70.0	3,500
Sludge Removal	10,000	0.0	0	100.0	10,000	10,000	0.0	0	100.0	10,000
Maintenance	18,000	60.0	10,800	40.0	7,200	13,000	50.0	6,500	50.0	6,500
Miscellaneous Supplies	3,000	80.0	2,400	20.0	600	3,000	80.0	2,400	20.0	600
Insurance	2,000	70.0	1,400	30.0	600	1,000	40.0	400	60.0	600
TOTALS	\$100,000		\$68,500		\$31,500	\$64,000		\$33,200		\$30,800

Incorrect?